

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com



**Workorder:** Sleepy Eye School (43636)  
**Account #:** 19366

**Client:** Sleepy Eye Public Schools

Tim Harbo  
Sleepy Eye Public Schools  
400 4th Avenue SW  
Sleepy Eye, MN 56085

**Certificate of Analysis****Approval**

All data reported has been reviewed and approved by:

Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:  
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:  
MN LAB # 038-999-267ND W/DW # ND-016

**Workorder Comments**

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

**Report Date:** Tuesday, April 9, 2024 1:23:44 PM

Page 1 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

**Lab ID:** 43636001 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 1 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Kitchen NE 2 Comp (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.54	ug/L	15	EPA 200.8	04/01/2024 17:14	

**Lab ID:** 43636002 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 2 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Kitchen SE 3 Comp RT (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:15	

**Lab ID:** 43636003 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 3 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Kitchen SE 3 Comp LFT (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:16	

**Lab ID:** 43636004 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 4 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Kitchen Steam Kettle

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.29	ug/L	15	EPA 200.8	04/01/2024 17:18	

**Lab ID:** 43636005 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 5 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Cafeteria (DF)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.59	ug/L	15	EPA 200.8	04/01/2024 17:19	

**Lab ID:** 43636006 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 6 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL 300 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.96	ug/L	15	EPA 200.8	04/01/2024 17:20	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

**Report Date:** Tuesday, April 9, 2024 1:23:44 PM

Page 2 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

**Lab ID:** 43636007 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 7 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL 300 (DF)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.85	ug/L	15	EPA 200.8	04/01/2024 17:21	

**Lab ID:** 43636008 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 8 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL 301 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.76	ug/L	15	EPA 200.8	04/01/2024 17:22	

**Lab ID:** 43636009 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 9 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Elem Hall by 301 (DF)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:23	

**Lab ID:** 43636010 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 10 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL Elem Hall by 301 (BF)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:24	

**Lab ID:** 43636011 **Date Collected:** 03/22/2024 04:30 **Matrix:** Potable Water  
**Sample ID:** 11 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL-302 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:32	

**Lab ID:** 43636012 **Date Collected:** 03/22/2024 04:40 **Matrix:** Potable Water  
**Sample ID:** 12 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** EL 303 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:33	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

**Report Date:** Tuesday, April 9, 2024 1:23:44 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

<b>Lab ID:</b>	43636013	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	13	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 304 (S)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:34

<b>Lab ID:</b>	43636014	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	14	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 305 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		0.59	ug/L	15	EPA 200.8	04/01/2024 17:35

<b>Lab ID:</b>	43636015	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	15	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Elem Hall by 303 (DF)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:36

<b>Lab ID:</b>	43636016	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	16	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 306 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:37

<b>Lab ID:</b>	43636017	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	17	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 307 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:38

<b>Lab ID:</b>	43636018	<b>Date Collected:</b>	03/22/2024 04:40	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	18	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 308 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:39

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 4 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

<b>Lab ID:</b> 43636019	<b>Date Collected:</b> 03/22/2024 04:40	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 19	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 309 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:40	
<b>Lab ID:</b> 43636020	<b>Date Collected:</b> 03/22/2024 04:40	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 20	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 310 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:41	
<b>Lab ID:</b> 43636021	<b>Date Collected:</b> 03/22/2024 04:40	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 21	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 311 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:50	
<b>Lab ID:</b> 43636022	<b>Date Collected:</b> 03/22/2024 04:40	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 22	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 312 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:51	
<b>Lab ID:</b> 43636023	<b>Date Collected:</b> 03/22/2024 04:50	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 23	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 313 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:52	
<b>Lab ID:</b> 43636024	<b>Date Collected:</b> 03/22/2024 04:50	<b>Matrix:</b> Potable Water				
<b>Sample ID:</b> 24	<b>Date Received:</b> 03/22/2024 08:02					
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b> EL 314 (s)						
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Copper	1.45	mg/L	1.3	EPA 200.7	04/09/2024 12:02	
Lead	2.81	ug/L	15	EPA 200.8	04/02/2024 11:51	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 5 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

<b>Lab ID:</b>	43636025	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	25	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 315 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		0.52	ug/L	15	EPA 200.8	04/01/2024 17:53

<b>Lab ID:</b>	43636026	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	26	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 316 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		0.54	ug/L	15	EPA 200.8	04/01/2024 17:54

<b>Lab ID:</b>	43636027	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	27	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 317 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		0.50	ug/L	15	EPA 200.8	04/01/2024 17:55

<b>Lab ID:</b>	43636028	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	28	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 318 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		0.83	ug/L	15	EPA 200.8	04/01/2024 17:56

<b>Lab ID:</b>	43636029	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	29	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Elem Hall by 318 (DF)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:57

<b>Lab ID:</b>	43636030	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	30	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL 319 (s)					
<b>Parameter</b>		<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>
Lead		<0.5	ug/L	15	EPA 200.8	04/01/2024 17:58

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 6 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

<b>Lab ID:</b>	43636031	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	31	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Elem Teacher's Lounge					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Copper	1.50	mg/L	1.3	EPA 200.7	04/02/2024 10:12	
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 17:59	

<b>Lab ID:</b>	43636032	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	32	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Nurse Office (s)					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 18:08	

<b>Lab ID:</b>	43636033	<b>Date Collected:</b>	03/22/2024 04:50	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	33	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Hall by 321 (DF)					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 18:09	

<b>Lab ID:</b>	43636034	<b>Date Collected:</b>	03/22/2024 05:00	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	34	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	EL Hall by 321 (BF)					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Copper	0.769	mg/L	1.3	EPA 200.7	04/02/2024 10:14	
Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 18:10	

<b>Lab ID:</b>	43636035	<b>Date Collected:</b>	03/22/2024 05:00	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	35	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	HS Choir Office (s)					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>
Lead	2.57	ug/L	15	EPA 200.8	04/01/2024 18:11	

<b>Lab ID:</b>	43636036	<b>Date Collected:</b>	03/22/2024 05:00	<b>Matrix:</b>	Potable Water	
<b>Sample ID:</b>	36	<b>Date Received:</b>	03/22/2024 08:02			
<b>Temp @ Receipt (C):</b>						
<b>Sample Desc:</b>	HS Wood Shop 121 (DF)					
<b>Parameter</b>	<b>Results</b>	<b>Units</b>	<b>MCL</b>	<b>Method</b>	<b>Analyzed</b>	<b>Qual</b>

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 7 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

Lead	<0.5	ug/L	15	EPA 200.8	04/01/2024 18:12
------	------	------	----	-----------	------------------

<b>Lab ID:</b> 43636037	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 37	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Ag Hall (DF)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	8.95	ug/L	15	EPA 200.8	04/01/2024 18:13	

<b>Lab ID:</b> 43636038	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 38	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS 105 (s)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	18.3	ug/L	15	EPA 200.8	04/01/2024 18:14	

<b>Lab ID:</b> 43636039	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 39	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Hall by 135 RT (DF)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	6.90	ug/L	15	EPA 200.8	04/01/2024 18:15	

<b>Lab ID:</b> 43636040	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 41	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS 135 (s)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	4.68	ug/L	15	EPA 200.8	04/01/2024 18:16	

<b>Lab ID:</b> 43636041	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 42	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS 129 (s)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	86.4	ug/L	15	EPA 200.8	04/01/2024 18:17	

<b>Lab ID:</b> 43636042	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 43	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Hall by 124 (DF)		

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/02/2024 07:56	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 8 of 18



**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

<b>Lab ID:</b> 43636043	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 44	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Hall by 124 (BF)		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>
Copper	0.447	mg/L 1.3 EPA 200.7 04/02/2024 10:15
Lead	<0.5	ug/L 15 EPA 200.8 04/02/2024 07:57

<b>Lab ID:</b> 43636044	<b>Date Collected:</b> 03/22/2024 05:00	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 45	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Concession (s)		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>
Lead	<0.5	ug/L 15 EPA 200.8 04/02/2024 07:58

<b>Lab ID:</b> 43636045	<b>Date Collected:</b> 03/22/2024 05:10	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 46	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Hall by 204 (DF)		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>
Lead	<0.5	ug/L 15 EPA 200.8 04/02/2024 07:59

<b>Lab ID:</b> 43636046	<b>Date Collected:</b> 03/22/2024 05:10	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 47	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Hall by 204 (BF)		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>
Lead	<0.5	ug/L 15 EPA 200.8 04/02/2024 08:00

<b>Lab ID:</b> 43636047	<b>Date Collected:</b> 03/22/2024 05:10	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 48	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Library (s)		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>
Lead	11.8	ug/L 15 EPA 200.8 04/02/2024 08:01

<b>Lab ID:</b> 43636048	<b>Date Collected:</b> 03/22/2024 05:10	<b>Matrix:</b> Potable Water
<b>Sample ID:</b> 49	<b>Date Received:</b> 03/22/2024 08:02	
<b>Temp @ Receipt (C):</b>		
<b>Sample Desc:</b> HS Home Ec Kitchen #1		
<b>Parameter</b>	<b>Results</b>	<b>Units</b> <b>MCL</b> <b>Method</b> <b>Analyzed</b> <b>Qual</b>

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 9 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

Copper	1.41	mg/L	1.3	EPA 200.7	04/02/2024 10:17
Lead	0.72	ug/L	15	EPA 200.8	04/02/2024 08:02

**Lab ID:** 43636049 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 50 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #2 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.40	ug/L	15	EPA 200.8	04/02/2024 08:03	

**Lab ID:** 43636050 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 51 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #3 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.72	ug/L	15	EPA 200.8	04/02/2024 08:04	

**Lab ID:** 43636051 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 52 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #4 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	2.99	ug/L	15	EPA 200.8	04/02/2024 08:05	

**Lab ID:** 43636052 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 53 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #5 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	6.10	ug/L	15	EPA 200.8	04/02/2024 08:14	

**Lab ID:** 43636053 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 54 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #6 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	20.0	ug/L	15	EPA 200.8	04/02/2024 08:15	

**Lab ID:** 43636054 **Date Collected:** 03/22/2024 05:10 **Matrix:** Potable Water  
**Sample ID:** 55 **Date Received:** 03/22/2024 08:02  
**Temp @ Receipt (C):**  
**Sample Desc:** HS Home Ec Kitchen #7 (s)

Parameter	Results	Units	MCL	Method	Analyzed	Qual
-----------	---------	-------	-----	--------	----------	------

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 10 of 18

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools**Analytical Results**

Lead	8.78	ug/L	15	EPA 200.8	04/02/2024 08:16	
<hr/>						
Lab ID:	43636055	Date Collected:	03/22/2024 05:10	Matrix:	Potable Water	
Sample ID:	56	Date Received:	03/22/2024 08:02			
Temp @ Receipt (C):						
Sample Desc:	HS Home Ec Kitchen #8 (s)					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	3.61	ug/L	15	EPA 200.8	04/02/2024 14:25	
<hr/>						
Lab ID:	43636056	Date Collected:	03/22/2024 05:20	Matrix:	Potable Water	
Sample ID:	57	Date Received:	03/22/2024 08:02			
Temp @ Receipt (C):						
Sample Desc:	HS Hall by 153 (DF)					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	04/02/2024 14:27	
<hr/>						
Lab ID:	43636057	Date Collected:	03/22/2024 05:20	Matrix:	Potable Water	
Sample ID:	58	Date Received:	03/22/2024 08:02			
Temp @ Receipt (C):						
Sample Desc:	HS Hall by Boy's Lockers (DF)					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.01	ug/L	15	EPA 200.8	04/02/2024 14:28	
<hr/>						
Lab ID:	43636058	Date Collected:	03/22/2024 05:20	Matrix:	Potable Water	
Sample ID:	59	Date Received:	03/22/2024 08:02			
Temp @ Receipt (C):						
Sample Desc:	HS Hall by 153 (BF)					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Copper	0.609	mg/L	1.3	EPA 200.7	04/03/2024 10:21	
Lead	<0.5	ug/L	15	EPA 200.8	04/02/2024 14:29	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 11 of 18



# MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com



Workorder: Sleepy Eye School (43636)

Client: Sleepy Eye Public Schools



Minnesota Valley Testing Laboratories, Inc.  
1126 North Front Street, Building 2  
New Ulm, MN 56073  
Phone: (507) 354-8517  
Toll Free: (800) 782-3557 Fax: (507) 359-2890

## Company Name and Address:

Sleepy Eye Public Schools  
400 14th Ave SW  
Sleepy Eye, MN 56085

Account #: 019366 Phone #: 507-357-5495

Billing Address (indicate if different from above):

Sleepy Eye Public Schools  
WO: 43636



Chain of Custody Record  
Page 1 of 6

Work Order #

Email: [timothyharbo@gmail.com](mailto:timothyharbo@gmail.com)

Contact (Report to):

Tim Harbo

Name of Samplers:

Tim Harbo

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Sleepy Eye School

Sample Condition: Received by:

AMB

B2

Date: Time: Temp:

22 Mar 24 8:02a 16.5

Transferred by:

1. Tim Harbo

Date:

Time:

Comments:

SP 22 Mar 24 0802

AMB 16.5 941

## Sample Information

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
01	1-EL-Kitchen-NE 2 Comp(s)	water	3/22/24	4:30	1	Lead
02	2-EL-Kitchen-SE 3 Comp RT(s)					
03	3-EL-Kitchen-SE 3 Comp LFT(s)					
04	4-EL-Kitchen-Steam Kettle					
05	5-EL-Culinary (DF)					
06	6-EL-300 (S)					
07	7-EL-300 (DF)					
08	8-EL-301 (S)					
09	9-EL-Elem Hall by 301 (DF)					
10	10-EL-Elem Hall by 301 (BF)					
11	11-EL-302 (S)					

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at [www.mvttl.com](http://www.mvttl.com) or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 12 of 18



# MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com



Workorder: Sleepy Eye School (43636)

Client: Sleepy Eye Public Schools



Minnesota Valley Testing Laboratories, Inc.  
1126 North Front Street, Building 2  
New Ulm, MN 56073  
Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890

## Company Name and Address:

Sleepy Eye Public Schools  
400 14th Ave SW  
Sleepy Eye, MN 56086

Account #: 019366 Phone #: 507-357-5495

Billing Address (Indicate if different from above):

Lab Use Only

Contact (Report to):  
Tim Harbo

Name of Samplers:  
Tim Harbo

Chain of Custody Record  
Page 2 of 6

Work Order # 43636

Email: timothyharbo@gmail.com

Quote Number: Date Submitted:  
Project Name/Number: Purchase Order #:  
Sleepy Eye School

Transferred by:	Date:	Time:	Sample Condition:	Received by:	Date:	Time:	Temp:
1.							
2.							

Comments:

SP 22 Mar 24 0802

AMB 16.5 941

## Sample Information

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
12	12-EL-303(s)	Water	3/22/24	4:40	1	Lead
13	13-EL-304(s)					
14	14-EL-305(s)					
15	15-EL-Elm Hall by 303 (DF)					
16	16-EL-306(s)					
17	17-EL-307(s)					
18	18-EL-308(s)					
19	19-EL-309(s)					
20	20-EL-310(s)					
21	21-EL-311(s)					
22	22-EL-312(s)					

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at [www.mvtl.com](http://www.mvtl.com) or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 13 of 18



**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools

Minnesota Valley Testing Laboratories, Inc.  
1126 North Front Street, Building 2  
New Ulm, MN 56073  
Phone: (507) 354-8517  
Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:  
Sleepy Eye Public Schools  
400 4th Ave SW  
Sleepy Eye, MN 56085

Account #: 019366 Phone #: 507-351-5495  
Billing Address (indicate if different from above):

Lab Use Only

**Chain of Custody Record**  
Page 3 of 6Work Order # 43636Email: timothyharbo@gmail.com

Contact (Report to):

Tim Harbo

Name of Samplers:

Tim Harbo

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Sleepy Eye School

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1.

2.

Comments:

SP 22 Mar 24 0802AMB 16.5 941**Sample Information**

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
<u>23</u>	<u>23-EL-313(S)</u>	<u>Water</u>	<u>3/22/24</u>	<u>4:50</u>	<u>1</u>	<u>Lead</u>
<u>24</u>	<u>24-EL-314(S)</u>					<u>Lead &amp; Copper</u>
<u>25</u>	<u>25-EL-315(S)</u>					<u>Lead</u>
<u>26</u>	<u>26-EL-316(S)</u>					<u>Lead</u>
<u>27</u>	<u>27-EL-317(S)</u>					<u>Lead</u>
<u>28</u>	<u>28-EL-318(S)</u>					<u>Lead</u>
<u>29</u>	<u>29-EL-Elem Hall by 318 (DF)</u>					<u>Lead</u>
<u>30</u>	<u>30-EL-319(S)</u>					<u>Lead</u>
<u>31</u>	<u>31-EL-Elem Teacher's Lounge</u>					<u>Lead &amp; Copper</u>
<u>32</u>	<u>32-EL-Nurse Office (S)</u>					<u>Lead</u>
<u>33</u>	<u>33-EL-Hall by 321 (DF)</u>					<u>Lead</u>

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at [www.mvtl.com](http://www.mvtl.com) or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

**Please submit the top two copies with your samples.**

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 14 of 18



# MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com



Workorder: Sleepy Eye School (43636)

Client: Sleepy Eye Public Schools



Minnesota Valley Testing Laboratories, Inc.  
1126 North Front Street, Building 2  
New Ulm, MN 56073  
Phone: (507) 354-8517  
Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:

Sleepy Eye Public School  
400 4th Ave SW  
Sleepy Eye, MN 56085

Account #: 019366 Phone #: 507-351-5495

Billing Address (indicate if different from above):

Lab Use Only

Chain of Custody Record  
Page 4 of 6

Work Order # 43636

Email: timothy.horbo@gmail.com

Contact (Report to):

Tim Harbo

Name of Samplers:

Tim Harbo

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Sleepy Eye School

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1.  
2.

Comments:

SP 22 Mar 24 0802

AMB 16.5 941

Sample Information

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
34	34 - Hall by 321 (BF)	Water	3/22/24	5:00	1	Lead & Copper
35	35 - HS - Choir Office (S)					Lead
36	36 - HS - Wood Shop 121 (DF)					Lead
37	37 - HS - Ag Hall (DF)					Lead
38	38 - HS - 185 (S)					Lead
39	39 - HS - Hall by 135 RT (DF)					Lead
40	40 - HS - 135 (S)					Lead
41	41 - HS - 129 (S)					Lead
42	42 - HS - Hall by 124 (DF)					Lead
43	43 - HS - Hall by 124 (BF)					Lead & Copper
44	44 - HS - Concussion (S)					Lead

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 15 of 18



# MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com



Workorder: Sleepy Eye School (43636)

Client: Sleepy Eye Public Schools



Minnesota Valley Testing Laboratories, Inc.  
1126 North Front Street, Building 2  
New Ulm, MN 56073  
Phone: (507) 354-8517  
Toll Free: (800) 782-3557 Fax: (507) 359-2890

## Company Name and Address:

Sleepy Eye Public School  
400 14th Ave SW  
Sleepy Eye, MN 56085

Account #: 019366 Phone #: 507-357-5495  
Billing Address (indicate if different from above):

Lab Use Only

Chain of Custody Record  
Page 5 of 6

Work Order # 43636

Email: [timothyharbo@gmail.com](mailto:timothyharbo@gmail.com)

Contact (Report to):

Tim Harbo

Name of Samplers:

Tim Harbo

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Sleepy Eye School

Sample Condition: Received by:

Date: Time: Temp:

Transferred by:	Date:	Time:						
1.								
2.								

Comments:

SP 22 Mar 24 0802

AMB 16.5 941

## Sample Information

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
45	46-HS-Hall by 204 (DF)	Water	3/22/24	510	1	Lead
46	47-HS-Hall by 204 (BF)					Lead
47	48-HS-Library (S)					Lead
48	49-HS-Home Ec Kitchen #1					Lead & Copper
49	50-HS-Home Ec Kitchen #2 (S)					Lead
50	51-HS-Home Ec Kitchen #3 (S)					Lead
51	52-HS-Home Ec Kitchen #4 (S)					Lead
52	53-HS-Home Ec Kitchen #5 (S)					Lead
53	54-HS-Home Ec Kitchen #6 (S)					Lead
54	55-HS-Home Ec Kitchen #7 (S)					Lead
55	56-HS-Home Ec Kitchen #8 (S)					Lead

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at [www.mvtl.com](http://www.mvtl.com) or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, April 9, 2024 1:23:44 PM

Page 16 of 18





**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724  
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.MVTL.com

**Workorder:** Sleepy Eye School (43636)**Client:** Sleepy Eye Public Schools

**MVTL LABORATORIES, Inc.** 1-800-782-3557

Date: 22 Mar 24 Time: 0802 ☒ AM ☐ PM By: SP

Account Name: IEA / Sleepy Eye Public Schools Account # 019366

Bill of Lading #: \_\_\_\_\_ Cooler #: \_\_\_\_\_

Temp: 16.5 °C ROI ☐ Ambient ☒ Tracking #: \_\_\_\_\_

TM#: 941 Ice Crystals Present In Sample ☐

MVTL Courier: \_\_\_\_\_ Other: \_\_\_\_\_

MVTL Route: \_\_\_\_\_ Walk-In ☒ UPS Air ☐ FedEx Air ☐ Speedee ☐

Mail ☐ UPS Ground ☐ FedEx Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH	
58	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO <sub>4</sub> Na <sub>2</sub> O <sub>3</sub> S <sub>2</sub> NONE HNO <sub>3</sub> H <sub>2</sub> SO <sub>4</sub> NaOH HCl SUB*	<2 >9 >12 N/A	Add
**I DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!**					
Low Level Mercury Kit		Clear Amber	MeOH None	n/a	
4 oz Jar		Clear Amber	MeOH None	n/a	
2 oz Jar		Clear Amber	HCl H <sub>3</sub> PO <sub>4</sub> H <sub>2</sub> SO <sub>4</sub> None	n/a	
Vials Individual Set of 2 Set of 3		Clear Amber	HCl H <sub>3</sub> PO <sub>4</sub> H <sub>2</sub> SO <sub>4</sub> None	n/a	
Vials Individual Set of 2 Set of 3		Clear Amber	HCl H <sub>3</sub> PO <sub>4</sub> H <sub>2</sub> SO <sub>4</sub> None	n/a	
Trip Blank Individual Set of 2 Set of 3			n/a		
Moisture Vial			n/a		
Manure Bottle			n/a		

\*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

**Report Date:** Tuesday, April 9, 2024 1:23:44 PM