

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: School Lead (65421)
Account #: 19366

Client: Sleepy Eye Public Schools

Tim Harbo
Sleepy Eye Public Schools
400 4th Avenue SW
Sleepy Eye, MN 56085

Certificate of Analysis**Approval**

All data reported has been reviewed and approved by:

Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM

Page 1 of 7

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** School Lead (65421)**Client:** Sleepy Eye Public Schools**Analytical Results**

Lab ID: 65421001 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 1 EL **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Elem Teacher's Lounge S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Copper	760	ug/L	1300	EPA 200.8	10/02/2024 11:14	

Lab ID: 65421002 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 2 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Library S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	19.2	ug/L	15	EPA 200.8	10/01/2024 11:25	

Lab ID: 65421003 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 3 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #1 S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Copper	2640	ug/L	1300	EPA 200.8	10/02/2024 11:15	

Lab ID: 65421004 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 4 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #5 S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	6.87	ug/L	15	EPA 200.8	10/01/2024 11:27	

Lab ID: 65421005 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 5 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #6 S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	14.0	ug/L	15	EPA 200.8	10/01/2024 11:29	

Lab ID: 65421006 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 6 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #7 S

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	5.45	ug/L	15	EPA 200.8	10/01/2024 11:42	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** School Lead (65421)**Client:** Sleepy Eye Public Schools**Analytical Results**

Lab ID: 65421007 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 7 EL **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Elem Teacher's Lounge S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Copper	902	ug/L	1300	EPA 200.8	10/02/2024 11:17	

Lab ID: 65421008 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 8 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Library S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	2.69	ug/L	15	EPA 200.8	10/01/2024 11:45	

Lab ID: 65421009 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 9 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #1 S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Copper	3290	ug/L	1300	EPA 200.8	10/02/2024 11:18	

Lab ID: 65421010 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 10 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #5 S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.56	ug/L	15	EPA 200.8	10/01/2024 11:47	

Lab ID: 65421011 **Date Collected:** 09/24/2024 05:30 **Matrix:** Potable Water
Sample ID: 11 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #6 S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.73	ug/L	15	EPA 200.8	10/01/2024 11:48	

Lab ID: 65421012 **Date Collected:** 09/24/2024 05:45 **Matrix:** Potable Water
Sample ID: 12 HS **Date Received:** 09/24/2024 08:26
Temp @ Receipt (C):
Sample Desc: Home Ec Kitchen #7 S Flush

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.53	ug/L	15	EPA 200.8	10/01/2024 11:49	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** School Lead (65421)**Client:** Sleepy Eye Public Schools**Analytical Results**

Lab ID:	65421013	Date Collected:	09/24/2024 05:45	Matrix:	Potable Water
Sample ID:	13	Date Received:	09/24/2024 08:26		
Temp @ Receipt (C):					
Sample Desc:	Library Coffee Maker				

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	10/01/2024 11:51	

Lab ID:	65421014	Date Collected:	09/24/2024 05:45	Matrix:	Potable Water
Sample ID:	14	Date Received:	09/24/2024 08:26		
Temp @ Receipt (C):					
Sample Desc:	Library Coffee Maker Flush				

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	10/01/2024 11:52	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: School Lead (65421)

Client: Sleepy Eye Public Schools



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073
Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:

Sleepy Eye Public
400 4th Ave SW
Sleepy Eye, MN 56085

Account #: 019366

Phone #: 507-351-5495

Billing Address (indicate if different from above):

Sleepy Eye Public Schools
WO: 65421



Chain of Custody Record
Page 1 of 2

Work Order #

Email:

Contact (Report to):

timothy.hartbo@gmail.com

Name of Samplers:

Tim Hartbo

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1. Tim Hartbo

2. Todd Leach 24 Sept 2024 9:26 20.6°C

Comments:

Am6 CM 24SEPT24 0826 20.6°C/mg41

TM941

Sample Information

Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
1	1-EL-Elm Teacher's Lounge (S)	Water	9/24/24	5:30	1	Copper
2	2-HS-Library (S)					Lead
3	3-HS-Home Ec Kitchen #1 (S)					Copper
4	4-HS-Home Ec Kitchen #5 (S)					Lead
5	5-HS-Home Ec Kitchen #6 (S)					Lead
6	6-HS-Home Ec Kitchen #7 (S)					Lead
7	7-EL-Elm Teacher's Lounge (S)-flush					Copper
8	8-HS-Library (S)-flush					Lead
9	9-HS-Home Ec Kitchen #1 (S)-flush					Copper
10	10-HS-Home Ec Kitchen #5 (S)-flush					Lead
11	11-HS-Home Ec Kitchen #6 (S)-flush					Lead

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvtl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM

Page 5 of 7



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: School Lead (65421)

Client: Sleepy Eye Public Schools



Sample Condition Checklist

Date: 24 Sept 24 Time: 0826 ☒ AM ☐ PM By: CM
Account Name: Sleepy Eye Public School Account # 019366
Bill of Lading #: _____ Cooler #: _____
Temp: 20.6 °C ROI ☐ Ambient ☒ Tracking #: _____
TM#: 941 Ice Crystals Present in Sample ☐ Other: _____
MVTL Courier: _____
MVTL Route: _____ Walk-in ☒ UPS Air ☐ FedEx Air ☐ SpeedDee ☐
Mail ☐ UPS Ground ☐ FedEx Ground ☐
Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type				Preservation					pH							
19	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G)	(P)	(AG)	(AP)	NaHSO ₄	Na ₂ O ₃ S ₂	NONE	HNO ₃	H ₂ SO ₄	NaOH	HCl	SUB*	<2	>9	>12	N/A	Add
	I DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!																	
	Low Level Mercury Kit																	
	4 oz Jar	Clear	Amber			MeOH			None								n/a	
	2 oz Jar	Clear	Amber			MeOH			None								n/a	
	Vials Individual Set of 2 Set of 3	Clear	Amber			HCl		H ₃ PO ₄	H ₂ SO ₄		None						n/a	
	Vials Individual Set of 2 Set of 3	Clear	Amber			HCl		H ₃ PO ₄	H ₂ SO ₄		None						n/a	
	Trip Blank Individual Set of 2 Set of 3								n/a									
	Moisture Vial								n/a									
	Manure Bottle								n/a									

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Wednesday, October 2, 2024 2:58:31 PM